

1 **Q. Re: Facility Rehabilitation (Pooled) - Please provide reliability and availability data**
2 **for the Horsechops Generating Plant over the past ten years.**

3
4 A. The Company uses the Plant Availability statistic as the key measure of overall plant
5 reliability and availability.

6
7 Table 1 shows the Plant Availability statistics for the generating unit at Horsechops for
8 the period 1998 to 2008.
9
10

Table 1
Plant Availability

| Year | Availability (%) |
|-------------------|-------------------------|
| 1998 | 95.73 |
| 1999 | 98.02 |
| 2000 | 96.82 |
| 2001 | 99.35 |
| 2002 | 74.95 |
| 2003 | 85.70 |
| 2004 | 91.50 |
| 2005 | 73.77 |
| 2006 | 95.54 |
| 2007 | 96.73 |
| 2008 ¹ | 98.77 |

11 ¹ 2008 data is inclusive to August 12, 2008.