2

1

- 3
- 4 5 6
- 7 8 9

10

- Re: Rocky Pond Plant Refurbishment (p. 2 of 81, Schedule B) Please provide Q. reliability and availability data for the Rocky Pond Plant over the past 10 years.
- A. The Company uses the Plant Availability statistic as a measure of overall plant reliability and availability.

Table 1 shows the Plant Availability statistics for the generating unit at Rocky Pond for the period 1998 to 2008.

Table 1 **Plant Availability**

Year	Availability (%)
1998	98.83
1999	97.10
2000	98.31
2001	98.40
2002	89.26
2003	91.07
2004	95.87
2005	87.27
2006	99.55
2007	98.71
2008^{1}	98.43

¹¹

¹ 2008 data is inclusive to August 12, 2008.