

1 Q. **Re: Replace Pump House Motor Control Centers-Holyrood, Vol. I, p. B-12; Vol. II -**  
2 **Tab 6**

3 Does NLH have protocols in place presently (ie. protective measures, etc.) in regard  
4 to the asbestos found in the pumphouses or any of its other sites that contain  
5 asbestos?  
6  
7

8 A. Yes, Hydro has Asbestos Management programs in place to manage and control all  
9 locations where asbestos exists. These asbestos management programs contain  
10 specific protocols for work methods to be followed for the safe removal and  
11 containment of asbestos. Asbestos locations are categorized as low, medium and  
12 high risk locations. For the low and medium risk locations, Hydro staff has been  
13 trained with standard work methods to contain and/or remove the asbestos. For  
14 those locations determined to be high risk, Hydro hires licensed contractors for the  
15 work.