

1 Q. **Re: Pole Replacements, Vol. II, Tab 14**

2 On page 4, NLH provides the number of poles to be replaced on each of the four  
3 lines identified. What proportion of each line's poles are proposed to be replaced  
4 in this project?

5

6

7 A. The proportion of poles to be replaced on each of the following lines is as follows:

8

9 Barachoix (L1) - 4%

10 English Harbour West (L1) – 2%

11 Fleur De Lys (L1) - 7%

12 Happy Valley (L4) - 9%