

1 Q. **Re: Distribution Line Upgrades 2010, Vol II, Tab 12**

2 It states at page 7: "The deteriorated components identified in each of these lines,  
3 were classified as "B" condition during the last inspection in 2006 and are  
4 scheduled to be replaced in 2010".

5 (A) Prior to the 2006 inspection, when were these lines last inspected?

6 (B) What was the classification of these lines when they were inspected prior to the  
7 2006 inspection?

8

9

10 A. (A) A visual inspection of distribution feeders in question is performed every eight  
11 years to evaluate the condition of the line; therefore prior to 2006, the lines in  
12 question were last inspected in 1998.

13

14 (B) Prior to 2006, the classifications of the poles for the lines in question were  
15 "Grade A - Excess of 5 years of life remaining".