

1 Q. **Install Diesel Fuel Tank Monitoring System at Ebbengunbaeg, Vol. I, p. c. 43**

2 Subsection 18 2 (a) of GAP (referred to at p. c-45) contemplates that the Minister
3 may accommodate remote installations by decreasing the frequency of dips relative
4 to the weekly standard. Has NLH sought the Minister's approval for bi-weekly dips
5 given the remote location in this instance?

6

7

8 A. Hydro has sought but not obtained approval for manual bi-weekly dips. Approval
9 has been granted for an automated level monitoring system at Cat Arm in lieu of
10 weekly dipping. A similar system will be installed at Ebbegunbaeg, if approved by
11 the Board.