

- 1 Q. **Install Diesel Fuel Tank Monitoring System at Ebbegunbaeg, Vol. I, p. c. 43**
- 2 How old are the bulk and 900 liter day storage tanks and of what material are they
- 3 constructed?
- 4
- 5
- 6 A. The bulk and 900 litre day storage tanks were installed in 2003. These steel tanks
- 7 were built according to industry material standard ULC-S601-2000, "Aboveground
- 8 Horizontal Shop Fabricated Steel Tanks."