

1    Q.    **Install Warm Air Make-up Access, Vol. II, p. D-6**

2            Has NLH had to have a rescue operation undertaken since 1992 when these  
3            enclosures were built?

4

5

6    A.    There have been no rescue operations undertaken since the enclosures were  
7            constructed. Regulations, however, require that standby rescue services are  
8            available whenever the confined space is entered.