

1 Q. Re: Replace Pump House Motor Control Centers-Holyrood, Vol. I, p. B-12; Vol. II -

2 Tab 6

3 What corrosive elements are found in the pumphouse environment?

4

5

6 A. The motor control centers are located in the main open equipment area of the

7 pumphouse. There are uncontrolled variations in temperature and humidity which

8 result in corrosion to electrical contacts and other components of the motor control

9 centers.