

- 1 Q. **Re Upgrade Gas Turbine Plant Life Extension - Hardwoods, page B-2**
- 2 Expand Appendix D to show power generation hours and synchronous condensing
- 3 hours.
- 4
- 5
- 6 A. Appendix D has been expanded below to show power generation hours and
- 7 synchronous condensing hours.

Operational Data for Hardwoods Gas Turbine Plant May 31, 2004 to May 31, 2009	
Operating Hours (power generation)	536
Synchronous Condensing Hours	22,770
Available but not Operating Hours	41,027
Forced Outage Hours	430
Maintenance Outage Hours	177
Planned Outage Hours	1,184
Number of Forced Outages	59
Number of Unit Starts	217