

1 Q. **Re Replace Programmable Logic Controllers, page B- 6**

2 What would be the projected useful service life of the proposed new Controllers?

3

4

5 A. According to the Invensys Life Cycle Phases plan for the controllers they should be
6 evaluated for upgrade at eight to ten years. The schedule for actual replacement of
7 the controllers will depend on the results of the evaluation.