

- 1 Q. **Re Upgrade Gas Turbine Plant Life Extension - Hardwoods, page B-2**
- 2 What has been the average number of starts and stops per year of the hardwoods
- 3 turbine since commissioning?
- 4
- 5
- 6 A. Operational data for Hardwoods gas turbine is available from January 1, 1991 to
- 7 June 1, 2009. During this time period of 18.4 years, 518 starts-stops have been
- 8 recorded, which is an average of 28.1 starts-stops per year.