

1 Q. **Re Upgrade Gas Turbine Plant Life Extension - Hardwoods, page B-2**

2 How does the increased availability of Holyrood units for use as synchronous
3 condensers affect the demand for use of the Hardwoods gas turbine as a
4 synchronous condenser?

5

6

7 A. In the context of the existing 230 kV transmission system east of Bay d’Espoir
8 Generating Station, operation of the Hardwoods gas turbine in synchronous
9 condenser mode along with Holyrood Unit 3 as a synchronous condenser and the
10 shunt capacitor banks at Hardwoods, Oxen Pond and Long Harbour Terminal
11 Stations, enables Hydro to maximize power deliveries to the Avalon Peninsula from
12 non thermal sources between mid spring and early fall without consuming fuel at
13 Holyrood. The system is configured such that power deliveries can be achieved
14 during loss of any one of the voltage support devices (i.e. synchronous condenser or
15 capacitor bank). In this context, as load on the eastern portion of the system
16 increases, one can expect the demand for all voltage support devices east of Bay
17 d’Espoir to increase.

18

19 In the context of an HVdc connection to the Island Interconnected System, there
20 will be an increased requirement for synchronous condensers on the Avalon
21 Peninsula. There are several reasons for this increased synchronous condenser
22 requirement. First, the line commutated converter technology used for HVdc
23 systems consumes reactive power (MVAR) at a level equal to approximately one
24 half of its power rating (MW). Therefore an 800 MW converter will consume
25 approximately 400 MVAR. While approximately one half of the MVAR requirement
26 is supplied by capacitor banks at the converter, the remainder must come from the
27 connected ac transmission system to ensure acceptable voltage response and

1 control. Given that the eastern portion of the system is heavily loaded, there is no
2 “spare” reactive power capacity to supply the HVdc converter station. As a result
3 additional synchronous condenser capacity will be required. Second, proper
4 operation of the HVdc converter station requires a minimum three phase short
5 circuit level. The existing three phase short circuit level must be increased to
6 provide the minimum acceptable level and the method of achieving the desired
7 increase is through the addition of synchronous machines (i.e. synchronous
8 condensers in this case). Finally, the increased synchronous condenser requirement
9 provides additional system inertia and voltage control through excitation system
10 action to provide acceptable system response during system disturbances.

11
12 The Hardwoods gas turbine in synchronous condenser mode, along with conversion
13 of all three units at Holyrood to synchronous condenser operation and installation
14 of three new synchronous condensers at the HVdc converter station will provide
15 the necessary support for successful integration of the HVdc converter station on
16 the Island Interconnected System. The synchronous condenser plan for the HVdc
17 has been envisioned to ensure continued operation for unplanned loss of any one
18 condenser. In this context, it is expected that all synchronous condensers will be
19 operated year round with individual units shut down only for scheduled
20 maintenance.

21
22 Beyond the synchronous condenser requirement of the Hardwoods gas turbine, gas
23 turbine capacity will continue to be required on the Island Interconnected System
24 to assist in meeting the Loss of Load Hours expectation criteria and to provide back
25 up generating capacity during outages to HVdc equipment.