

---

1    Q.    **C-172, Replace Radomes, \$211,700**

2            On page 180 of the project description it is stated that: "The cost of a microwave  
3            failure today would be far more significant than the incident of 1996 due to the fact  
4            that teleprotection signals, are now transmitted using the microwave network."

5            Are primary protection signals or backup signals transmitted using the microwave  
6            network?

7

8

9    A.    Primary protection signals are transmitted using the microwave network.