

**Q. Substations - Additions to Load Growth - p. 20 of 96 - Could the relocation of the 17 MVA Deer Lake substation transformer to Mobile be deferred beyond 2010?**

**A.** No. The transformer overloads at Deer Lake Substation and Mobile Substation necessitate upgrading transformer capacity at both locations in 2010. The relocation of the Deer Lake transformer to Mobile is a critical part of addressing both overloads, and is part of the least cost alternative.<sup>1</sup>

---

<sup>1</sup> Reference 2.2 2010 Additions Due to Load Growth, page 7, Table 2.