

1 **Q. Substations - Additions to Load Growth - p. 20 of 96 - Deer Lake and Mobile**
2 **substation projects - is there an industry or engineering standard as to when a**
3 **substation transformer should be replaced by reason of age and/or loading?**
4

5 A. Newfoundland Power is not aware of an industry or engineering standard as to when
6 substation transformers are to be replaced due to age or loading. As long as a substation
7 transformer can be maintained in good condition and can perform a useful function, then
8 the transformer will either be kept in service or function as a spare. A transformer is
9 retired when its condition is such that it cannot be economically refurbished or the
10 transformer is no longer useful as a spare.

11
12 An important tool used in recent years in the management of transformer life has been
13 periodic transformer oil dissolved gas analysis. It has enabled Newfoundland Power to
14 detect when some types of transformer problems occur and repair or replace the
15 transformers before failure. It has been instrumental in managing some transformers to
16 the end of their useful lives without a significant end of life failure event.

17
18 Newfoundland Power refers to American International Standards Institute (“ANSI”)
19 standard C57.92, *Guide for Loading Oil-immersed Distribution and Power Transformers*,
20 in the assessment of when a substation transformer is to be replaced or otherwise
21 offloaded due to loading. ANSI standard C57.92 is based upon the guidance of the
22 Institute of Electrical and Electronic Engineers (“IEEE”).
23

24 When a substation transformer is forecast to exceed its nameplate rating, Newfoundland
25 Power assesses the engineering options available to address the situation within the
26 context of appropriate standards. These standards do not, however, simply indicate when
27 a transformer is to be replaced by reason of age and/or loading.