

**Facility Rehabilitation (Pooled), p. 2 of 96, \$1,340,000**

**Q. What is the normal level of production of each of the hydro plants included in this project?**

**A.** Table 1 includes the normal production level for each of the hydro plants referenced in section 2.0 of report *1.1 2010 Facility Rehabilitation*.

**Table 1**  
**Normal Annual Production**  
**(GWh)**

<b>Hydro Plant</b>	<b>Production</b>
Heart's Content	8.3
Lawn	2.5
Pierre's Brook	23.4
Port Union	2.3
Seal Cove	8.5
Rocky Pond	14.1
West Brook	2.9