

**Lookout Brook Hydro Plant Refurbishment (Clustered), p. 4 of 96, \$2,155,000**

**Q. In the report provided in Tab 1.2 Lookout Brook Hydro Plant Refurbishment, page 7, NP mentions “arc flash zone of influence”. If NP has investigated the extent of arc flash exposure in its facilities please provide the report that has been prepared. If not, please provide reasons why this investigation has not been undertaken.**

**A.** Newfoundland Power has not prepared a formal report on arc flash exposure for all of its facilities.

Newfoundland Power has investigated the extent of arc flash exposure and completed arc flash hazard studies for all of its substation and hydro plant high voltage switchgear. Such studies are completed to current industry standards under the supervision of qualified professional engineers.


Attachment A provides the arc flash study for Lookout Brook Plant. The *arc flash zone of influence* for the switchgear at Lookout Brook Plant is 633 inches or 16 metres.

**Lookout Brook  
Arc Flash Hazard Study**

## ELECTRICAL ENGINEERING

### ARC FLASH HAZARD STUDY

Company Area:	Stephenville	
Switchgear Included:	LBK 2.4kV	
Prepared by:	D. Jones	Date:




### REASON FOR ARC FLASH HAZARD STUDY

Arc Flash Hazard calculations to be done for all Metal Clad Switchgear.  
Study revisited after 403L conversion from 33kV to 66kV.

### POINTS TO NOTE

1. PPE level class >4 at 16 inches (working inside switchgear).
2. PPE level class 3 at 36 inches (racking out breaker).



# SINGLE LINE DIAGRAM

**NEWFOUNDLAND**  
**POWER**  
 A FORTIS COMPANY

PROVINCE OF NEWFOUNDLAND  
 PERMIT HOLDER



This Permit Allows

NEWFOUNDLAND POWER INC.

To practice Professional Engineering  
 in Newfoundland and Labrador.  
 Permit No. as issued by APEGN N0124  
 which is valid for the year 2009

## LOOKOUT BROOK

Date: 2009-03-18

Page 1 Of 1

App:

SLD No. 8-913



X/R ratio for above.	-2.94
Assymetry factor based on X/R ratio	1.3
Assymetrical LG fault level	161.2

S & C 66.00 kV asymmetrical interrupting rating (MVA)	1673.00
--	---------

S & C 66.00 kV symmetrical interrupting rating (MVA)	1046.00
---	---------

(If the rating is higher than the fault levels above,  
the selected fuse can interrupt these faults. A lower  
X/R ratio for the fault levels above will allow a higher  
safety margin.)

Determine fusing ratio //////////////////////////////////////

Fusing ratio = Fuse rating / Xfmr self-cooled MVA rating

Transformer self-cooled MVA rating	7.50
Full load amps at 66.00 kV	65.6
Transformer MVA rating with full cooling	10.00
Full load amps at 66.00 kV	87.5

Select a fuse size	80
Fuse letter code	E
Fusing ratio with above	1.22
Corresponding rating (MVA)	18.29
Simple overload capacity	183%
(Transformer FL / 2 x fuse rating)	

(A fuse will normally carry approximately 2X its current rating  
before it will start to melt.)

Impedance limited secondary faults may reduce the short circuit current to  
the order of 500-1000 % of the transformer rated full-load current.  
Overcurrents of this magnitude definitely accelerate transformer aging and  
should be cleared promptly. This basically requires a low fusing ratio.  
S&C recommends that fusing ratios should be less than 1.5 and no greater  
than 2.0.

<b>LOCATION</b> -----	Lookout Brook
Device	LBK-T1-FD
Fuse Manufacturer	S&C
Manufacturer's designation	SMD-1A
kV rating	69
Size	80E
Fuse speed rating	Standard
Holder type	SMD-1A
Manufacturer's catalog number	
Curve numbers	153-1, 153-1-6-1

COMMENTS:

<b>LOCATION</b> -----	Lookout Brook	
Relay type	MCGG22	
System kV	66.00	
CT Ratio:1	20	(100:5)
CT connection	Y	
Rated current of the CT secondary (In)	5	
 DEVICE --->	LBK-T1-51N	
Relay range (increments of 0.05)	0.05-2.4	
Range in secondary amps (Is) (relay range x In)	0.25-12	
Pickup setting (Is/In)	----->	0.2
Pickup setting, sec. amps (Is) (pickup x In)	1.00	
Time multiplier (0.025-1)(increments of 0.025)	----->	0.30
MVA setting	2.29	
Operating Curve	----->	Very Inverse
 DEVICE --->	LBK-T1-50NLV	
Relay range (increments of 1)	1-31	
Range in secondary amps (relay range x Is)	(5-155) x Is	
Pickup setting	----->	N/A
Pickup setting, sec. amps (pickup x Is)	0.00	
MVA setting	0.00	

COMMENTS //

Change the Pickup setting from 0.4 (2.3 MVA @ 33KV) to 0..2 (2.3 MVA @ 66 KV).



## Convert 403L to 66 KV

### STG-403L-P143

#### Phase Settings

I>1 Function	<u>IEC E Inverse</u>
I>1 Direction	<u>Non-Directional</u>
I>1 Current	<u>Set 111.0 A</u>
I>1 TMS	<u>100.0e-3</u>
I>1 tRESET	<u>0 s</u>
I>2 Function	<u>Disabled</u>
I>3 Status	<u>Enabled</u>
I>3 Direction	<u>Non-Directional</u>
I>3 Current Set	<u>795.0 A</u>
I>3 Time Delay	<u>0 s</u> <i>30 ms</i> <i>CJS</i>
I>4 Status	<u>Disabled</u>
I> Blocking	<u>001111</u>
I> Char Angle	<u>45.00 deg</u>
V CONTROLLED	<u>O/C</u>
VCO Status	<u>Disabled</u>

1. Change I>1 Function from IEC v Inverse to IEC E Inverse.
2. Change I>1 TMS from 0.350 to 0.100
3. Change I>1 Current from 201 amps to 111 amps.
4. Change I>3 Current set from 1359 amps to 795 amps.

*FROM APPROVED 403L CONVERSION  
COORDINATION STUDY.*



# Maximum Generation Fault LBK 2.4 kV

## Faulted Bus -> (I) report

Faulted Bus	Bus Id	Type	Prefault kV	Fault type	Fault S [MVA]	Ia [A]	Ia [deg]	Ib [A]	Ib [deg]	Ic [A]	Ic [deg]	In [A]	In [deg]
LBK 02	LBK 02		2.4	LLL	100	23994.75	-82.9135	23994.75	157.0865	23994.75	37.0865	0	0
First Ring Contributions													
LBK 02	LBK G1	Generator	2.4	LLL	34	8191.156	-90	8191.156	150	8191.156	30	0	0
LBK 02	LBK T1	Xmer	2.4	LLL	66	15898.69	-79.2697	15898.69	160.7303	15898.69	40.7303	0	0

## Global Current Report

Faulted Bus	Branch id	Type	Fault type	Branch Side	Ia [A]	Ia [deg]	Ib [A]	Ib [deg]	Ic [A]	Ic [deg]	In [A]	In [deg]
LBK 02	403L(B)	Line	LLL	ROB 403L-D3	578	130.7353	578	10.7353	578	-109.265	0	0
LBK 02	403L(B)	Line	LLL	LBK T1-A	578	-49.2647	578	-169.265	578	70.7353	0	0


Minimum Generation Fault LBK 2.4 kV. LBK plant on.

Faulted Bus -> (I) report

Faulted Bus	Bus Id	Type	Prefault kV	Fault type	Fault S [MVA]	Ia [A]	Ia [deg]	Ib [A]	Ib [deg]	Ic [A]	Ic [deg]	In [A]	In [deg]
LBK 02	LBK 02		2.4	LLL	92	22066.52	-83.7537	22066.52	156.2463	22066.52	36.2463	0	0
First Ring Contributions													
LBK 02	LBK T1	Xmer	2.4	LLL	58	13952.89	-80.092	13952.89	159.908	13952.89	39.908	0	0
LBK 02	LBK G1	Generator	2.4	LLL	34	8191.156	-90	8191.156	150	8191.156	30	0	0

Global Current Report

Faulted Bus	Branch id	Type	Fault type	Branch Side	Ia [A]	Ia [deg]	Ib [A]	Ib [deg]	Ic [A]	Ic [deg]	In [A]	In [deg]
LBK 02	403L(B)	Line	LLL	ROB 403L-D3	507.2	129.913	507.2	9.913	507.2	-110.087	0	0
LBK 02	403L(B)	Line	LLL	LBK T1-A	507.2	-50.087	507.2	-170.087	507.2	69.913	0	0



Breaker clearing time 0.3064 Max Gen  
 Breaker clearing time 0.4028 Min Gen  
 Fuse clearing time 0.6040 Max Gen.  
 Fuse clearing time 0.7809 Min Gen.

PLOTTING VOLTAGE:66 kV

BY: D. Jones


Plot shows miscoordination between Breaker and Fuse.

DATE: 7-24-2009

*LBK - 2.4KV FAULT*



MVA: x 1 at 66 kV



Breaker clearing time 0.3064 Max Gen  
Breaker clearing time 0.4028 Min Gen  
Fuse clearing time 0.6040 Max Gen.  
Fuse clearing time 0.7809 Min Gen.

PLOTTING VOLTAGE:66 kV

BY: D. Jones

Plot shows miscoordination between Breaker and Fuse.

DATE: 7-24-2009

LBK = 2.4 kV FAULT

**Arc Flash Hazard LBK 2.4 kV with 80E fuses installed on LBK-T1 transformer. 403L converted to 66 kV  
IEEE standard**

Faulted Bus	Generation	Fault	Fault Current	CT	CT Plus Fuses	Working Distance	Flash Hazard Boundry	cal / cm2	PPE Level	L.A.B.	R.A.B.	P.A.B.
LBK 2.4	Max	LLL	23995	0.6040	0.6040	16"	533	37.24	4	60"	26"	7"
LBK 2.4	Min	LLL	22067	0.7809	0.7809	16"	633	44.06	>4	60"	26"	7"

Faulted Bus	Generation	Fault	Fault Current	CT	CT Plus Fuses	Working Distance	Flash Hazard Boundry	cal / cm2	PPE Level	L.A.B.	R.A.B.	P.A.B.
LBK 2.4	Max	LLL	23995	0.6040	0.6040	36"	533	16.91	3	60"	26"	7"
LBK 2.4	Min	LLL	22067	0.7809	0.7809	36"	633	20.00	3	60"	26"	7"

**\*Arc Flash Calculated for Switchgear and fixed conductor.  
Software won't supply Arc Flash results for clearing times over one second.**

**L.A.B.** Limited Approach Boundry  
**R.A.B.** Restricted Approach Boundry  
**P.A.B.** Prohibited Approach Boundry

Miscoordination between STG-403L-B and LBK-T1 fuses for 2.4 kV bus fault.  
Used fuse Clearing Time for Arc Flash Study as this would be worst case.

## IEEE 1584 Based Arc Flash Calculator and Warning Label Creator

Equipment Class Switchgear ☐

Gap between Conductors 104 mm.

Grounding Type Grounded ☐

Working Distance 406.4 mm.

Available 3 Phase Bolted Current 23.995 kA

System Voltage 2400 Volt

☒ I agree to be bound with Terms & Conditions of this website.

Calculate Boundaries

**Equipment Type:** Switchgear

**Typical Gap bw. Electrodes:** 104mm.

**Grounding:** Grounded

**Work Distance:** 406.4 mm.

**Arc Duration @ Predicted Arcing Current:** 0.6040 sec.

**Arc Duration @ 15% Reduced Arc Current :** 0.6040 sec.

**Available 3Ø Bolted Current:** 23.995 kA

**Predicted 3Ø Arcing Current:** 22940 A

**System Voltage L-L:** 2400 Volt

<u>Calculation Mode</u>	<u>Incident Energy Exposure (cal/cm<sup>2</sup>)</u>	<u>Flash Protection Boundary (inches)</u>	<u>Level of PPE</u>
@ 100% Arcing Current	37.24	533	4
@ 85% Arcing Current	31.24	445	4

## IEEE 1584 Based Arc Flash Calculator and Warning Label Creator

Equipment Class Switchgear ☐

Gap between Conductors 104 mm.

Grounding Type Grounded ☐

Working Distance 406.4 mm.

Available 3 Phase Bolted Current 22.067 kA

System Voltage 2400 Volt

☒ I agree to be bound with Terms & Conditions of this website.

Calculate Boundaries

**Equipment Type:** Switchgear

**Typical Gap bw. Electrodes:** 104mm.

**Grounding:** Grounded

**Work Distance:** 406.4 mm.

**Arc Duration @ Predicted Arcing Current:** 0.7809 sec.

**Arc Duration @ 15% Reduced Arc Current :** 0.7809 sec.

**Available 3Ø Bolted Current:** 22.067 kA

**Predicted 3Ø Arcing Current:** 21130 A

**System Voltage L-L:** 2400 Volt

<u>Calculation Mode</u>	<u>Incident Energy Exposure (cal/cm<sup>2</sup>)</u>	<u>Flash Protection Boundary (inches)</u>	<u>Level of PPE</u>
@ 100% Arcing Current	44.06	633	N/A
@ 85% Arcing Current	36.96	528	4

633 inches  
39.54 inches = 16. meters



## IEEE 1584 Based Arc Flash Calculator and Warning Label Creator

Equipment Class Switchgear ☐

Gap between Conductors 104 mm.

Grounding Type Grounded ☐

Working Distance 914.4 mm.

Available 3 Phase Bolted Current 23.995 kA

System Voltage 2400 Volt

☒ I agree to be bound with Terms & Conditions of this website.

Calculate Boundaries

**Equipment Type:** Switchgear

**Typical Gap bw. Electrodes:** 104mm.

**Grounding:** Grounded

**Work Distance:** 914.4 mm.

**Arc Duration @ Predicted Arcing Current:** 0.6040 sec.

**Arc Duration @ 15% Reduced Arc Current :** 0.6040 sec.

**Available 3Ø Bolted Current:** 23.995 kA

**Predicted 3Ø Arcing Current:** 22940 A

**System Voltage L-L:** 2400 Volt

<u>Calculation Mode</u>	<u>Incident Energy Exposure (cal/cm<sup>2</sup>)</u>	<u>Flash Protection Boundary (inches)</u>	<u>Level of PPE</u>
@ 100% Arcing Current	16.91	533	3
@ 85% Arcing Current	14.19	445	3

## IEEE 1584 Based Arc Flash Calculator and Warning Label Creator

Equipment Class Switchgear ☐

Gap between Conductors 104 mm.

Grounding Type Grounded ☐

Working Distance 914.4 mm.

Available 3 Phase Bolted Current 22.067 kA

System Voltage 2400 Volt

☒ I agree to be bound with Terms & Conditions of this website.

Calculate Boundaries

**Equipment Type:** Switchgear

**Typical Gap bw. Electrodes:** 104mm.

**Grounding:** Grounded

**Work Distance:** 914.4 mm.

**Arc Duration @ Predicted Arcing Current:** 0.7809 sec.

**Arc Duration @ 15% Reduced Arc Current :** 0.7809 sec.

**Available 3Ø Bolted Current:** 22.067 kA

**Predicted 3Ø Arcing Current:** 21130 A

**System Voltage L-L:** 2400 Volt

<u>Calculation Mode</u>	<u>Incident Energy Exposure (cal/cm<sup>2</sup>)</u>	<u>Flash Protection Boundary (inches)</u>	<u>Level of PPE</u>
@ 100% Arcing Current	20.00	633	3
@ 85% Arcing Current	16.78	528	3



## WARNING

### Arc Flash and Shock Hazard Appropriate PPE Required

**16.08** Flash Hazard Boundary  
**44.1** cal / cm<sup>2</sup> Flash Hazard at **406 mm**  
**>4** PPE Level **De-energize Switchgear or Change  
Protection Settings to Reduce Hazard  
Category**

**Inside Any Switchgear Cubicle Compartment**

**2400** VAC Shock Hazard

Equipment Name **LBK 2.4kV**



## WARNING

### Arc Flash and Shock Hazard Appropriate PPE Required

**16.08** Flash Hazard Boundary  
**20.0** cal / cm<sup>2</sup> Flash Hazard at **914 mm**  
**3** PPE Level **Flash Suit or Insulated Pants and Jacket;  
Hard Hat; Safety Glasses; Flash Suit  
Hood; Hearing, Hand & Foot Protection**

**Breaker Operation - Open or Close**

**Breaker Operation - Racking**

**2400** VAC Shock Hazard

Equipment Name **LBK 2.4kV**



## WARNING

### Arc Flash and Shock Hazard Appropriate PPE Required

**3 m** Flash Hazard Boundary  
**8** cal / cm<sup>2</sup> Flash Hazard at **914 mm**  
**2** PPE Level **Flash Suit or FR Work Shirt With Either  
Flash Pants or FR Coverall & Denim Pants  
Hard Hat; Safety Glasses; Arc Rated Face  
Shield; Hearing, Hand & Foot Protection**

**Breaker Operation With Cubicle Door Fully Secured**

**2400** VAC Shock Hazard

Equipment Name **LBK 2.4kV**