

1 **Q. With regard to NP thermal generation, please provide a table showing the following**
2 **for each of the With regard to NP thermal generation, please provide a table**
3 **showing the following for each of the past five years: date of dispatch, time of**
4 **dispatch, time of recall, amount of generation dispatched, and reason for dispatch**
5 **including whether NP- or Hydro-initiated. Please also show the NP peak demand at**
6 **the time of dispatch, and the NP peak demand for the particular year.**

7
8 A. Attachment A contains the data requested regarding the dispatch of Newfoundland
9 Power's thermal generation.

10
11 Newfoundland Power's peak demand at the time of dispatch is not available.
12 Newfoundland Power's SCADA or Plant Availability applications do not archive the
13 system peak demand at the time the thermal generation was dispatched. However, the
14 daily system demand is available and is provided in Attachment A.

Newfoundland Power Thermal Generation Dispatch

Newfoundland Power Thermal Generation Dispatch

Date	Generator	Start Time	End Time	Amount (MW)	Daily Peak (MW)	Native Peak (MW)	Initiated By	Reason
11/23/2003	Greenhill	6:20 AM	12:40 PM	12.3	634.7	1118.3	NP	Planned work providing local load
12/5/2003	Greenhill	11:52 AM	12:44 PM	14.5	902.0	1099.5	NP	Planned work Salt Pond substation
4/25/2004	Wesleyville	9:33 PM	6:45 PM	3.9	784.9	1099.5	NP	Storm damage 116L, operated for ~ 21 hours
6/22/2004	Wesleyville	6:35 AM	8:22 AM	5.7	750.4	1099.5	NP	Scheduled outage on 115L
7/8/2004	Wesleyville	5:12 AM	8:53 AM	5.0	509.7	1099.5	NP	Switching at Gambo substation
7/22/2004	Mobile Diesel	3:40 PM	5:50 PM	2.0	500.6	1099.5	Hydro	Scheduled outage on TL215
7/23/2004	Mobile Diesel	5:30 AM	12:30 pm	1.0	510.9	1099.5	Hydro	Hydro crews working at Doyles substation
7/23/2004	PAB Diesel	3:30 PM	4:30 PM	1.5	510.9	1099.5	Hydro	Hydro crews working at Doyles substation
7/23/2004	Mobile Diesel	3:55 PM	4:50 PM	1.0	510.9	1099.5	Hydro	Hydro crews working at Doyles substation
8/2/2004	PAB Diesel	8:00 AM	7:20 PM	2.0	493.7	1099.5	Hydro	Scheduled outage on TL214
8/2/2004	Mobile Diesel	10:35 AM	1:40 PM	2.0	493.7	1099.5	Hydro	Scheduled outage on TL214
8/2/2004	Mobile Diesel	4:35 PM	5:50 PM	2.0	493.7	1099.5	Hydro	Scheduled outage on TL214
8/3/2004	PAB Diesel	7:20 AM	8:55 PM	2.0	479.2	1099.5	Hydro	Scheduled outage on TL214
8/3/2004	Mobile Diesel	9:15 AM	1:30 PM	2.0	479.2	1099.5	Hydro	Scheduled outage on TL214
8/3/2004	Mobile Diesel	3:35 PM	6:45 PM	2.0	479.2	1099.5	Hydro	Scheduled outage on TL214
8/4/2004	PAB Diesel	7:10 AM	6:50 PM	2.0	474.9	1099.5	Hydro	Scheduled outage on TL214
8/4/2004	Mobile Diesel	9:05 AM	5:40 PM	2.0	474.9	1099.5	Hydro	Scheduled outage on TL214
8/5/2004	Mobile Diesel	7:05 AM	2:40 PM	2.0	485.0	1099.5	Hydro	Scheduled outage on TL214
8/5/2004	PAB Diesel	8:55 AM	5:55 PM	2.0	485.0	1099.5	Hydro	Scheduled outage on TL214
8/5/2004	Mobile Diesel	4:45 PM	6:55 PM	2.0	485.0	1099.5	Hydro	Scheduled outage on TL214
8/6/2004	Mobile Diesel	7:15 AM	1:05 PM	2.0	478.3	1099.5	Hydro	Scheduled outage on TL214
8/6/2004	PAB Diesel	10:15 AM	7:05 PM	2.0	478.3	1099.5	Hydro	Scheduled outage on TL214
8/6/2004	Mobile Diesel	3:55 PM	6:00 PM	2.0	478.3	1099.5	Hydro	Scheduled outage on TL214
8/7/2004	PAB Diesel	8:06 AM	5:45 PM	2.0	456.2	1099.5	Hydro	Scheduled outage on TL214
8/7/2004	Mobile Diesel	10:20 AM	1:55 PM	2.0	456.2	1099.5	Hydro	Scheduled outage on TL214
8/7/2004	Mobile Diesel	3:55 PM	6:33 PM	2.0	456.2	1099.5	Hydro	Scheduled outage on TL214
8/8/2004	Mobile Diesel	10:40 AM	2:40 PM	2.0	464.2	1099.5	Hydro	Scheduled outage on TL214
8/8/2004	PAB Diesel	12:40 PM	5:29 PM	2.0	464.2	1099.5	Hydro	Scheduled outage on TL214
8/9/2004	PAB Diesel	8:00 AM	7:10 PM	2.0	485.0	1099.5	Hydro	Scheduled outage on TL214
8/9/2004	Mobile Diesel	9:30 AM	2:25 PM	2.0	485.0	1099.5	Hydro	Scheduled outage on TL214
8/9/2004	Mobile Diesel	6:15 PM	6:56 PM	2.0	485.0	1099.5	Hydro	Scheduled outage on TL214
8/10/2004	PAB Diesel	7:30 AM	6:15 PM	2.0	477.9	1099.5	Hydro	Scheduled outage on TL214
8/10/2004	Mobile Diesel	9:45 AM	1:15 PM	2.0	477.9	1099.5	Hydro	Scheduled outage on TL214
8/10/2004	Mobile Diesel	4:10 PM	5:45 PM	2.0	477.9	1099.5	Hydro	Scheduled outage on TL214
8/11/2004	PAB Diesel	7:20 AM	6:08 PM	2.0	477.4	1099.5	Hydro	Scheduled outage on TL214
8/11/2004	Mobile Diesel	9:28 AM	9:50 PM	2.0	477.4	1099.5	Hydro	Scheduled outage on TL214
8/11/2004	Mobile Diesel	10:15 AM	1:30 PM	2.0	477.4	1099.5	Hydro	Scheduled outage on TL214
8/11/2004	Mobile Diesel	4:15 PM	5:40 PM	2.0	477.4	1099.5	Hydro	Scheduled outage on TL214
8/12/2004	PAB Diesel	7:43 AM	5:50 PM	2.0	480.5	1099.5	Hydro	Scheduled outage on TL214

Newfoundland Power Thermal Generation Dispatch

Date	Generator	Start Time	End Time	Amount (MW)	Daily Peak (MW)	Native Peak (MW)	Initiated By	Reason
8/12/2004	Mobile Diesel	10:10 AM	1:30 PM	2.0	480.5	1099.5	Hydro	Scheduled outage on TL214
8/12/2004	Mobile Diesel	3:50 PM	5:40 PM	2.0	480.5	1099.5	Hydro	Scheduled outage on TL214
8/13/2004	PAB Diesel	9:35 AM	2:10 PM	2.0	487.7	1099.5	Hydro	Scheduled outage on TL214
8/13/2004	PAB Diesel	3:20 PM	5:47 PM	2.0	487.7	1099.5	Hydro	Scheduled outage on TL214
8/14/2004	Mobile GT	10:20 AM	1:30 PM	2.0	449.7	1099.5	Hydro	Scheduled outage on TL214
8/14/2004	PAB Diesel	10:20 AM	1:30 PM	2.0	449.7	1099.5	Hydro	Scheduled outage on TL214
8/14/2004	PAB Diesel	4:00 PM	5:30 PM	2.0	449.7	1099.5	Hydro	Scheduled outage on TL214
8/15/2004	Mobile GT	4:00 PM	5:30 PM	2.0	458.3	1099.5	Hydro	Scheduled outage on TL214
9/8/2004	Mobile Diesel	2:07 PM	7:17 PM	1.7	503.9	1099.5	NP	Unit on line at ROB substation
9/21/2004	Mobile Diesel	6:38 AM	8:10 AM	1.9	616.0	1099.5	NP	Unit on line at ROB substation, 403L Rebuild
9/22/2004	Mobile Diesel	6:45 AM	9:37 PM	1.8	615.1	1099.5	NP	Unit on line at ROB substation, 403L Rebuild
9/23/2004	Mobile Diesel	6:30 AM	7:05 PM	1.2	582.4	1099.5	NP	Unit on line at ROB substation, 403L Rebuild
9/24/2004	Mobile Diesel	6:30 AM	3:20 PM	1.8	567.0	1099.5	NP	Unit on line at ROB substation, 403L Rebuild
10/24/2004	PUN Diesel	10:00 AM	6:00 PM	0.6	631.9	1099.5	NP	Scheduled outage on 123L
11/4/2004	Wesleyville	9:17 AM	4:28 PM	6.3	824.5	1099.5	NP	Scheduled outage on 116L
11/22/2004	Greenhill	10:30 AM	12:15 AM	15.0	845.6	1099.5	Hydro	Off load TL212 for Hydro crews
11/29/2004	Greenhill	10:57 AM	12:39 PM	17.0	859.0	1099.5	Hydro	Off load TL212 for Hydro crews
12/8/2004	Greenhill	8:45 AM	9:32 PM	19.1	989.6	1167.3	Hydro	Off load TL212 for Hydro crews
3/30/2005	Wesleyville	4:04 PM	7:22 PM	10.0	825.3	1167.3	NP	Bus lockout at Gambo substation
4/14/2005	Wesleyville	12:56 PM	5:50 AM	6.0	783.6	1167.3	NP	Pole broke on 116L
8/11/2005	Mobile Diesel	5:50 AM	4:44 PM	1.5	496.7	1167.3	Hydro	Scheduled outage on TL215
8/11/2005	Mobile GT	6:00 AM	4:45 PM	1.6	496.7	1167.3	Hydro	Scheduled outage on TL215
9/2/2005	Greenhill	1:00 PM	1:50 PM	19.0	510.6	1167.3	Hydro	Hydro requests all available generation
9/2/2005	Mobile GT	1:12 PM	1:30 PM	5.0	510.6	1167.3	Hydro	Hydro requests all available generation
9/22/2005	Greenhill	9:44 AM	2:30 PM	0.5	531.4	1167.3	Hydro	Unit ran as synchronous condenser
9/26/2005	Greenhill	10:26 AM	11:33 AM	10.0	593.7	1167.3	Hydro	Off load TL212 for Hydro crews
10/3/2005	Greenhill	10:21 AM	11:03 AM	10.0	554.4	1167.3	Hydro	Off load TL212 for Hydro crews
12/13/2005	Greenhill	5:53 AM	7:13 AM	13.5	906.6	1130.9	NP	Planned work providing local load
1/23/2006	Greenhill	7:22 AM	2:02 PM	20.0	1151.1	1130.9	Hydro	Hydro requests all available generation
1/23/2006	Wesleyville	7:48 AM	7:55 PM	8.0	1151.1	1130.9	Hydro	Hydro requests all available generation
1/23/2006	Mobile GT	8:15 AM	2:06 PM	6.5	1151.1	1130.9	Hydro	Hydro requests all available generation
1/23/2006	Mobile Diesel	8:19 AM	2:04 PM	2.0	1151.1	1130.9	Hydro	Hydro requests all available generation
1/23/2006	Greenhill	4:22 PM	9:03 PM	20.0	1151.1	1130.9	Hydro	Hydro requests all available generation
1/23/2006	PAB Diesel	4:22 PM	9:08 PM	2.5	1151.1	1130.9	Hydro	Hydro requests all available generation
1/23/2006	Mobile Diesel	4:32 PM	9:08 PM	2.0	1151.1	1130.9	Hydro	Hydro requests all available generation
1/23/2006	Mobile GT	4:35 PM	9:00 PM	6.5	1151.1	1130.9	Hydro	Hydro requests all available generation
3/7/2006	PAB Diesel	12:24 PM	4:25 PM	2.5	853.4	1130.9	Hydro	Scheduled outage on TL215
3/7/2006	Mobile Diesel	12:27 PM	2:24 PM	2.0	853.4	1130.9	Hydro	Scheduled outage on TL215
3/7/2006	Mobile GT	12:47 PM	4:21 PM	3.7	853.4	1130.9	Hydro	Scheduled outage on TL215

Newfoundland Power Thermal Generation Dispatch

Date	Generator	Start Time	End Time	Amount (MW)	Daily Peak (MW)	Native Peak (MW)	Initiated By	Reason
3/16/2006	Wesleyville	11:54 AM	3:06 PM	8.0	799.9	1130.9	NP	Scheduled outage on 115L
5/15/2006	Mobile Diesel	9:45 AM	7:06 PM	2.0	590.6	1130.9	NP	Scheduled outage on 358L
6/6/2006	Mobile Diesel	11:37 AM	6:30 PM	2.0	561.7	1130.9	NP	Feeder upgrades Lewiporte substation
6/13/2006	Mobile Diesel	6:30 AM	5:05 PM	3.0	544.6	1130.9	NP	Feeder upgrades Lewiporte substation
8/31/2006	PAB Diesel	7:20 AM	2:05 PM	1.8	531.1	1130.9	Hydro	Scheduled outage on TL215
8/31/2006	Mobile GT	7:47 AM	2:06 PM	1.8	531.1	1130.9	Hydro	Scheduled outage on TL215
11/17/2006	PAB Diesel	12:30 PM	3:15 PM	2.0	620.8	1130.9	Hydro	Scheduled outage on TL214
11/17/2006	Mobile Diesel	12:35 PM	3:20 PM	1.5	620.8	1130.9	Hydro	Scheduled outage on TL214
11/17/2006	Mobile GT	12:55 PM	3:15 PM	3.5	620.8	1130.9	Hydro	Scheduled outage on TL214
1/31/2007	Greenhill	11:16 AM	12:05 PM	15.0	1035.5	1142.0	Hydro	switching for TL212 maintenance
5/8/2007	Wesleyville	9:56 PM	12:00 AM	10.0	761.5	1142.0	NP	emergency - running all local load
5/9/2007	Wesleyville	12:00 AM	3:16 PM	10.0	648.8	1142.0	NP	emergency - running all local load
7/16/2007	Greenhill	6:29 AM	10:34 AM	8.0	532.6	1142.0	Hydro	voltage support for work at SUN
7/17/2007	Greenhill	6:19 AM	12:01 PM	8.0	533.4	1142.0	Hydro	voltage support for work at SUN
7/17/2007	Greenhill	12:16 PM	12:26 PM	14.0	533.4	1142.0	Hydro	voltage support for work at SUN
7/17/2007	Greenhill	12:39 PM	1:26 PM	14.0	533.4	1142.0	Hydro	carry load due to system problems
7/31/2007	Mobile GT	6:35 AM	10:31 PM	2.5	522.7	1142.0	Hydro	for Hydro work on TL214
7/31/2007	PAB Diesel	6:35 AM	8:53 PM	2.5	522.7	1142.0	Hydro	for Hydro work on TL215
8/2/2007	Mobile GT	7:30 AM	3:37 PM	2.5	496.9	1142.0	Hydro	TL215 work
8/14/2007	Greenhill	6:45 AM	6:27 PM	4.6	503.4	1142.0	Hydro	10 hours synch condense
8/17/2007	Greenhill	2:04 PM	6:25 PM	10.0	519.2	1142.0	Hydro	generation and voltage support for SUN outage
9/24/2007	Greenhill	9:41 AM	11:47 AM	12.0	547.8	1142.0	Hydro	for SUN outage
11/20/2007	Greenhill	9:24 AM	10:24 AM	18.6	896.2	1142.0	Hydro	to allow Hydro switching on TL212
12/5/2007	Mobile Diesel	5:45 PM	6:30 PM	1.5	904.0	1181.0	NP	Bonavista area load - emergency
12/6/2007	Mobile Diesel	5:45 PM	6:30 PM	1.5	904.0	1181.0	NP	Bonavista area load - emergency
12/7/2007	Mobile Diesel	5:45 PM	6:30 PM	1.5	904.0	1181.0	NP	Bonavista area load - emergency
12/20/2007	Greenhill	8:02 AM	8:52 AM	10.0	904.0	1181.0	NP	Bonavista area load - emergency
1/20/2008	Mobile GT	12:25 PM	12:50 PM	2.0	989.9	1181.0	Hydro	all available - Duff's problem
1/20/2008	Greenhill	12:01 PM	12:26 PM	10.0	989.9	1181.0	Hydro	all available - Duff's problem
1/20/2008	Greenhill	4:57 PM	6:36 PM	20.0	989.9	1181.0	Hydro	all available - Duff's problem
1/22/2008	Mobile GT	7:23 AM	9:20 AM	2.0	1194.1	1181.0	Hydro	all available - for peaking
1/22/2008	Greenhill	4:02 PM	6:16 PM	10.0	1194.1	1181.0	Hydro	all available - for peaking
4/10/2008	Greenhill	8:42 AM	4:28 PM	5.0	741.9	1181.0	Hydro	load and voltage support for work at SUN
5/13/2008	Mobile Diesel	7:32 AM	3:41 PM	0.5	807.7	1181.0	NP	Planned work providing load to Glovertown feeders
5/14/2008	Mobile Diesel	7:30 AM	5:51 PM	0.5	808.2	1181.0	NP	Planned work providing load to Glovertown feeders
5/15/2008	Mobile Diesel	7:22 AM	4:14 PM	0.5	799.5	1181.0	NP	Planned work providing load to Glovertown feeders
5/15/2008	Greenhill	8:47 AM	9:40 AM	14.0	799.5	1181.0	Hydro	switching for Hydro on TL212
5/21/2008	Mobile Diesel	6:19 AM	8:37 PM	0.5	668.2	1181.0	NP	Planned work providing load to Glovertown feeders
5/22/2008	Mobile Diesel	6:20 AM	5:10 PM	0.5	676.7	1181.0	NP	Planned work providing load to Glovertown feeders

Newfoundland Power Thermal Generation Dispatch

Date	Generator	Start Time	End Time	Amount (MW)	Daily Peak (MW)	Native Peak (MW)	Initiated By	Reason
5/26/2008	Mobile Diesel	10:00 AM	6:33 PM	0.5	623.2	1181.0	NP	Planned work providing load to Glovertown feeders
5/27/2008	Mobile Diesel	7:36 AM	3:28 PM	0.5	616.2	1181.0	NP	Planned work providing load to Glovertown feeders
5/28/2008	Mobile Diesel	7:34 AM	4:28 PM	0.5	631.2	1181.0	NP	Planned work providing load to Glovertown feeders
5/29/2008	Mobile Diesel	6:00 AM	1:48 PM	0.3	621.0	1181.0	NP	Planned work providing load to Glovertown feeders
6/5/2008	Mobile Diesel	5:50 AM	3:08 PM	0.5	546.7	1181.0	NP	Planned work providing load to Glovertown feeders
6/9/2008	Mobile Diesel	12:00 PM	7:27 PM	0.5	595.7	1181.0	NP	Planned work providing load to Glovertown feeders
6/10/2008	Mobile Diesel	5:55 AM	4:29 PM	0.5	613.5	1181.0	NP	Planned work providing load to Glovertown feeders
6/11/2008	Mobile Diesel	8:20 AM	3:47 PM	0.5	633.9	1181.0	NP	Planned work providing load to Glovertown feeders
7/3/2008	Mobile GT	1:39 PM	2:49 PM	2.0	522.6	1181.0	NP	Planned work providing load to Twillingate feeders
7/4/2008	Mobile GT	8:27 AM	11:00 AM	5.6	510.1	1181.0	NP	Planned work providing load to Twillingate feeders
7/6/2008	Mobile GT	6:55 PM	7:37 PM	1.7	483.4	1181.0	NP	Planned work providing load to Twillingate feeders
7/7/2008	Mobile GT	6:15 AM	5:00 PM	3.8	507.3	1181.0	NP	Planned work providing load to Twillingate feeders
7/8/2008	Mobile GT	6:25 AM	3:28 PM	3.9	506.9	1181.0	NP	Planned work providing load to Twillingate feeders
7/9/2008	Mobile GT	6:00 AM	11:28 AM	3.9	514.1	1181.0	NP	Planned work providing load to Twillingate feeders
8/16/2008	TRP Diesel	2:06 PM	7:06 PM	1.1	478.4	1181.0	NP	emergency - 95L out of service
8/19/2008	Mobile GT	7:40 AM	4:57 PM	4.8	507.9	1181.0	NP	planned work on 115L
8/26/2008	Greenhill	11:39 AM	12:42 PM	13.0	511.8	1181.0	NP	Salt Pond substation planned work
9/5/2008	Mobile GT	6:15 AM	5:50 PM	3.5	500.7	1181.0	NP	planned work on 402L
9/6/2008	Mobile GT	6:05 AM	5:00 PM	2.8	475.4	1181.0	NP	planned work on 402L
9/8/2008	Mobile GT	6:10 AM	3:30 PM	2.8	524.1	1181.0	NP	planned work on 410L
9/9/2008	Mobile GT	6:10 AM	5:48 PM	2.8	512.1	1181.0	NP	planned work on 410L
9/10/2008	Mobile GT	6:08 AM	5:46 PM	2.8	526.1	1181.0	NP	planned work on 410L
9/11/2008	Mobile GT	6:35 AM	5:46 PM	2.8	507.8	1181.0	NP	planned work on 410L
10/16/2008	Mobile GT	7:00 AM	6:16 PM	3.4	613.4	1181.0	Hydro	Hydro work on TL215
10/16/2008	Mobile Diesel	7:00 AM	6:16 PM	2.0	613.4	1181.0	Hydro	Hydro work on TL215
10/17/2008	Mobile GT	8:00 AM	6:14 PM	3.4	583.4	1181.0	Hydro	Hydro work on TL215
10/17/2008	Mobile Diesel	8:00 AM	6:14 PM	2.0	583.4	1181.0	Hydro	Hydro work on TL215
10/18/2008	Mobile Diesel	6:55 AM	5:55 PM	2.0	620.1	1181.0	Hydro	Hydro work on TL215
10/18/2008	Mobile GT	6:55 AM	5:55 PM	4.0	620.1	1181.0	Hydro	Hydro work on TL215
10/22/2008	Greenhill	10:10 AM	11:58 AM	18.0	775.6	1181.0	NP	Salt Pond work
10/24/2008	Greenhill	8:56 AM	11:56 AM	15.0	782.1	1181.0	Hydro	DUF-G2 problem
11/18/2008	Mobile GT	7:21 AM	5:10 PM	3.5	785.1	1181.0	NP	load from Broad Cove feeder
11/19/2008	Mobile GT	7:19 AM	4:38 PM	3.5	742.0	1181.0	NP	load from Broad Cove feeder
11/23/2008	Mobile GT	9:23 AM	2:39 PM	4.2	811.7	1181.0	NP	load from Broad Cove feeder
12/9/2008	Greenhill	8:53 AM	4:52 AM	5.0	1048.7	1219.0	Hydro	TL219 isolated for maintenance
12/10/2008	Greenhill	7:23 AM	1:20 AM	5.0	886.9	1219.0	Hydro	TL219 isolated for maintenance
12/11/2008	Greenhill	7:15 AM	3:47 AM	5.0	944.8	1219.0	Hydro	TL219 isolated for maintenance
12/15/2008	Mobile GT	7:11 AM	6:00 PM	4.6	948.6	1219.0	NP	load of Cape Broyle and Fermuse feeders
12/17/2008	Greenhill	4:09 PM	8:42 PM	20.0	1019.0	1219.0	Hydro	Duff's unit offline

Newfoundland Power Thermal Generation Dispatch

Date	Generator	Start Time	End Time	Amount (MW)	Daily Peak (MW)	Native Peak (MW)	Initiated By	Reason
12/17/2008	Mobile GT	4:03 PM	8:50 PM	5.0	1019.0	1219.0	Hydro	Hydro requests all available generation
12/17/2008	TRP Diesel	3:46 PM	6:03 PM	1.0	1019.0	1219.0	Hydro	Hydro requests all available generation
12/17/2008	Wesleyville	4:10 PM	6:51 PM	6.0	1019.0	1219.0	Hydro	Hydro requests all available generation
12/18/2008	TRP Diesel	4:00 PM	5:41 PM	1.0	1022.7	1219.0	Hydro	Hydro requests all available generation
12/18/2008	Greenhill	3:40 PM	6:24 PM	10.0	1022.7	1219.0	Hydro	Hydro requests all available generation
12/18/2008	Wesleyville	3:46 PM	6:03 PM	6.0	1022.7	1219.0	Hydro	Hydro requests all available generation
3/12/2009	Mobile GT	12:40 PM	3:30 PM	6.7	1026.0	1219.0	Hydro	TL214 work
3/12/2009	Mobile Diesel	12:40 PM	3:30 PM	2.2	1026.0	1219.0	Hydro	TL214 work
3/12/2009	PAB Diesel	12:40 PM	3:30 PM	2.5	1026.0	1219.0	Hydro	TL214 work
4/4/2009	Wesleyville	11:00 PM	2:00 AM	9.0	735.8	1219.0	NP	emergency - Gambo substation
5/21/2009	Wesleyville	8:03 AM	1:13 PM	6.8	653.5	1219.0	NP	planned work at Gambo substation

Notes:

- [1] Daily peak demand is the daily System Peak as reported by the SCADA system, and is not necessarily coincident with the operation of the thermal generator
- [2] Native Peak is the peak load on Newfoundland Power's system before weather adjustment
- [3] Data covers the period October 2003 to May 2009
- [4] Newfoundland Power's Plant Availability application archives operational data commencing in October 2003
- [5] Includes only generator operations where customer load was supplied, does not include unit testing