

Q. For the Island Interconnected System, please provide a breakdown of customer interruptions both in terms of frequency and number of minutes owing to generation-, transmission- and distribution-related causes.

A. Newfoundland Power does not have the data requested for the Island interconnected system.

Table 1 provides a breakdown of customer interruptions between Distribution and Loss of Supply for the customers served by Newfoundland Power for the period 2004 to 2008.

Table 1
Customer Interruptions by Source
2004 - 2008

	Frequency of Interruptions (SAIFI)			Outage Hours/Customer (SAIDI)		
	Distribution	Loss of Supply	Total	Distribution	Loss of Supply	Total
2004	2.08	1.51	3.59	3.18	1.69	4.87
2005	1.61	1.60	3.21	2.50	1.03	3.53
2006	1.70	1.20	2.90	2.17	0.81	2.98
2007	1.70	1.60	3.30	5.15	1.31	6.46
2008	1.54	1.30	2.84	2.01	0.79	2.80

Loss of Supply includes interruptions attributable to both generation and transmission.