

Q. Re Rattling Brook Dam Refurbishment, Tab 1.3

What maintenance has taken place on the Rattling Brook spillway since 2005?

A. Since the commissioning of Rattling Brook plant in 1958, with the exception of the replacement of the deteriorated stoplogs and other minor upgrades, the spillway is in its original condition.

Since 2005, maintenance items have been limited to the replacement of deteriorated planks on the working platform, replacement of deteriorated planks on the catwalk and foundation improvements to the steel support braces. These maintenance items were required to ensure employee and public safety.