

1 **Q. Re Sandy Brook Hydro Plant Refurbishment (other) p. 10 of 100 and Tab 1.4.**

2
3 **Please provide plant availability statistics for the Sandy Brook Plant for the past 5**
4 **years.**

5
6 **A.** Table 1 provides the plant availability statistics for the Sandy Brook hydro plant for the
7 past 5 years.
8
9

Table 1
Sandy Brook Hydro Plant Availability
2005 – 2010

Period	Forced Downtime (%)	Maintenance Downtime (%)	Planned Downtime (%)	Plant Availability (%)
2010 ¹	1.06%	0.27%	0.00%	98.67%
2009	0.04%	0.12%	0.89%	98.95%
2008	0.40%	0.30%	0.10%	99.20%
2007	0.57%	0.30%	0.09%	99.05%
2006	0.05%	0.16%	0.03%	99.77%
2005	0.16%	0.11%	0.15%	99.58%

¹ Includes January 1 through August 13, 2010.