

1 **Q. At page 18 (of 90) in Schedule “B” of the Substations section, what is the rationale**  
2 **for the termination of a new feeder at the Kelligrews substation at a cost of**  
3 **\$148,000.00? This project is not addressed in the Report at tab 2.2.**  
4

5 A. At page 18 (of 90) in Schedule “B” of the Substations section, item 3 involves the  
6 termination of a new feeder at the Kelligrews substation at a cost of \$148,000.00. This  
7 Substation project is required as a result of the addition of a new feeder in the Kelligrews  
8 area of the Town of Conception Bay South. The rationale for this new feeder is provided  
9 in the report at Tab 4.2 titled *Feeder Additions for Load Growth*.<sup>1</sup> Tab 4.2 provides  
10 information on projects at the distribution feeder level which are required due to  
11 electrical system load growth.  
12

13 The report at Tab 2.2 titled *2012 Additions Due to Load Growth* provides information on  
14 projects at the substation level which are required due to electrical system load growth.

---

<sup>1</sup> See Section 2.3 Overloaded Feeders of the report at Tab 4.2 titled *Feeder Additions for Load Growth* for the rationale for constructing a new feeder from Kelligrews substation to Legion Road.