

1 **Q. Will the Transmission Line Rebuild (Tab 3.1) cause disruption to customers?**

2
3 A. The three transmission line rebuild projects in the 2012 Transmission Line Rebuild report
4 (Tab 3.1) have no planned customer interruptions.

- 5
6 • Transmission Line 110L - The project to rebuild 110L will be completed during the
7 time of year when the customer load is at a level where other transmission lines on
8 the Bonavista Peninsula can carry the load.
9 • Transmission line 21L – This line connects Horse Chops Hydroelectric Plant to the
10 grid at Transmission Line 20L, and carries no customer load.
11 • Transmission line 124L – This line which is between Clarenville and Gambo will be
12 removed from service for construction but will not cause customer disruption, as
13 transmission line 124L is part of the looped transmission system in Central
14 Newfoundland¹.

¹ During construction customers served by Gambo substation will be fed through Stoney Brook east to Gambo.
Customers served by Clarenville substation will be fed from Sunnyside west to Clarenville.