Q. Please restate Figure 6 at p.9 to include NP's usage of Hydro's P2.

A. Figure 1 provides a restatement of figure 6 at page 9 of the report at Tab 2.4 titled *Portable Substation Study* including Newfoundland Power's usage of Newfoundland and Labrador Hydro's portable substation P2.

50 45 40 35 30 25 20 15 10 5 2007 2008 2009 2010 2011F

Duration of Portable Substation In Service (Weeks)

Figure 1

■ Portable P2 ■ Portable P3

Portable P4

The addition of Newfoundland Power's usage of portable substation P2 to Figure 1 does not inform the discussion on the overall availability of portable substations, as the figure does not include the usage of portable substation P2 by Hydro for their own purposes. Portable substation P2 can only be used at 35 out of the total 192 transformer locations. The inclusion of Hydro's portable substation P2 does not change the recommendation of the report included at Tab 2.4 *Portable Substation Study* to purchase a new 50 MVA portable substation.

■ Portable P1

Table 1 in Response to Request for Information CA NP 007 provides the revised summary of power transformers and portable substation backup capability including Hydro's portable substation P2.