

- 1   **Q.     Re: Portable Substation. Please provide details of NP's use of Hydro's P2 from 2007**  
2   **to 2011(f).**  
3  
4   A.     Newfoundland Power has used Newfoundland and Labrador Hydro's portable substation  
5           P2 only once in the 5-year period from 2007 to 2011(f). This was for a 9-week period in  
6           2007 while transformer T1 at Goulds substation was temporarily removed from service.