

1 Q. Re: 2013 Capital Projects 500,000 and Over: p. C-8 Upgrade Governor controls on  
2 Units 1 and 2:  
3 These were installed in 2003 and 1999 on Units 1 and 2 respectively. Are both  
4 entering the obsolete phase at the same time in 2014?

5

6

7 A. The turbine controllers on Units 1 and 2 are General Electric (GE) Mark V and both  
8 will enter the obsolescence phase in 2014 as per a notice from GE. Refer to Pages  
9 A5 to A7 (Mark V/EX2000 to Mark VI/EX2100 Control Product Transition) and A15  
10 (Mark V End of Life) in Appendix A of the report for further information.