

1 Q. Re: 2013 Capital Projects 500,000 and Over: p. C-10 Upgrade Gas Turbine Controls  
2 (Happy Valley):  
3 What is the expect remaining life duration of the existing control system?

4

5

6 A. The life cycle of the existing control system has expired. It is an obsolete system  
7 and it is not known how much longer the control system will operate.