

1 Q. Re: 2013 Capital Projects 500,000 and Over: p. C-16. Install Backup System for Raw
2 Water Supply and Clarifier:
3 How long will the backup system be required?
4
5

6 A. The primary requirement for the back-up systems is to ensure an adequate supply
7 of raw water until the Holyrood plant ceases its capability for power generation,
8 which is projected to be the year 2020. While the raw water system will still be
9 required after the Holyrood plant ceases power production, this project's primary
10 justification is based on mitigating the risks to business continuity in the plant's
11 current operational state. The risk is more severe due to the age of the assets and
12 Holyrood production requirements increasing leading up to 2017.