

1 Q. Re: 2013 Capital Projects 500,000 and Over: p. C-20 Upgrade Vibration Monitoring
2 Equipment (Holyrood):
3 When will the vendor cease to provide repair or exchange of components?
4
5

6 A. The vendor will cease to provide repair or exchange of components once the
7 system enters the obsolescence phase, which has not yet been identified. Typically,
8 the last date to repair is issued several months prior to transition to the
9 obsolescence phase.