

- 1 Q. Re: 2013 Capital Projects 500,000 and Over: Explanations, page C-22 Upgrade Fuel
2 Oil Day Tank:
3 How long has the American Petroleum Institute standard 653 been in place?
4
5
6 A. The first edition of this standard was issued on January 1, 1991. Hydro has already
7 applied this standard to the larger tanks in Holyrood.