

1 Q. Re: 2013 Capital Projects 500,000 and Over: p. C-22 Upgrade Fuel Oil Day Tank  
2 (Holyrood):

3 Hydro states at p. C-22 that its condition is unknown. Given this, how does Hydro  
4 know what refurbishment will entail or cost?

5

6

7 A. Hydro does not know what refurbishment will entail or cost, however, with  
8 consideration to the age of the tank, and Hydro's experience working on storage  
9 tanks that have been in service under similar circumstances, it is anticipated that  
10 the fuel oil day tank at Holyrood will require repairs. The exact scope of  
11 refurbishment will not be known until a full tank inspection is completed. However,  
12 it is believed that the allowance of \$120,000 in the budget for this work is  
13 reasonable.