

1 Q. Re: 2013 Capital Projects 200,000 and Over but less than 500,000: Explanations,
2 pages D-2 through D-7 Install Cold-Reheat Condensate Drains and High-Pressure
3 Heater Trip Level Unit 3:

4 Has there been any issues with the drain pots on Units One and Two since
5 implementation?
6

7
8 A. There have been no issues with the drain pots on Units 1 and 2 since
9 implementation.