

1 Q. Re: 2013 Capital Projects Over 200,000 but less than 500,000: p. D-51 Replace
2 Automatic Transfer Switches:
3 What is the basis for the statement at p. D-54 that the “automatic transfer switch
4 has an estimated service life of 30 years”?

5

6

7 A. A 2009 depreciation study by Gannett Fleming Inc. includes automatic transfer
8 switches in the unit of property C15 for Control, Meter/Relaying, with a whole life
9 of 30 years.