

1 Q. Re: 2013 Capital Projects Over 200,000 but less than 500,000: p. D-161
2 Install Online Vibration Monitoring System:
3 At p. D-197, isn't the recommendation at the second bullet to monitor weekly?
4 Spectrum is not expressly recommending that a permanent monitor be installed;
5 they are merely pointing out that there are a number of ways to permanently
6 monitor. Is this not the case?

7

8

9 A. The recommendation that is being put forward by Spectrum is not to monitor
10 weekly as a permanent solution, but to only monitor weekly until the vibration
11 problems had been corrected. The recommended solution was outlined in the
12 bullets that followed, and were to:

- 13 • Verify and correct alignment;
14 • Reduce the unbalance of the rotating assembly; and
15 • Verify the air gaps during correction procedure.

16

17 In the same document, Spectrum recommended the permanent online vibration
18 monitoring solution.