

- 1 Q. Re: 2013 Capital Projects Over 200,000 but less than 500,000: p. D-210  
2 Install Additional Washrooms (Various Sites):  
3 Has Hydro inquired with enforcement officials of the OHSA Regulations as regards  
4 allowances to employers which maintain facilities that are remote and infrequently  
5 visited by employees?  
6  
7  
8 A. Enforcement officials of the Provincial OHSA Regulations were contacted via  
9 telephone on June 28, 2012. Discussions were held regarding the remote nature  
10 and infrequent usage of the facilities. Hydro was informed that, under the  
11 regulations, no allowances would be granted to these facilities and that if male and  
12 female workers are expected to conduct work at the facility then separate  
13 washrooms are required.