

1 Q. Re: 2013 Capital Projects Over 50,000 but less than 200,000: p. E-2 Install  
2 Automated Fuel Monitoring System (Upper Salmon):  
3 How many more fuel tanks is Hydro planning to install such a monitoring system  
4 on?

5

6

7 A. In the current 20 year plan, four other tanks are scheduled to be retrofitted with  
8 the same type of monitoring system:

- 9 • West Salmon Spillway (2014);  
10 • Paradise River Plant (2017);  
11 • Granite Canal (2018); and  
12 • Victoria Control Structure (2020).

13 It should be noted that Hydro has not yet completed its consideration of whether  
14 other fuel systems (e.g. diesel plants) require automated monitoring.