

- 1 Q. Re: 2013 Capital Projects Over 50,000 but less than 200,000: p. E-2 Install  
2 Automated Fuel Monitoring System (Upper Salmon):  
3 What is the age of the tank at this site?  
4  
5  
6 A. Both the bulk tank and the day tank are seven years old (manufactured in 2005).