

1 Q. Re: 2013 Capital Projects Over 50,000 but less than 200,000: p. E-2 Install
2 Automated Fuel Monitoring System (Upper Salmon):
3 How many times did personel (*sic*) visit this site in 2011 for dips and other reasons?
4
5

6 A. Operations preventive maintenance (PM) inspections are conducted monthly.
7 Several PM inspections are conducted on the same trip. There was 100 percent
8 compliance for environmental PMs at North Salmon spillway in 2011, which
9 resulted in 12 visits for dips.
10

11 Heavy duty mechanics perform a PM on the diesel generator annually. This is
12 typically scheduled at the same time as an operations PM since an operator is
13 required for isolation purposes. The general maintenance personnel perform a
14 structural inspection annually, and perform dam inspections monthly at this site.
15 Operators rarely have to travel to this site to respond to alarms or perform a visual
16 inspection of the site after spilling. However, abnormally high water levels in 2011
17 resulted in 13 visits to North Salmon spillway for this purpose.