

1 Q. Re: Unit 3 Turbine Valves Overhaul, Tab 6:

2 When was the last overhaul prior to 2010?

3

4

5 A. Prior to 2010, the last overhaul on the turbine valves of Unit 3 was in 2007 and was
6 included as part of the major turbine/generator overhaul for that unit. Please see
7 the response to CA-NLH-119 for further information.