

1 Q. Re: Upgrade Unit Vibration Monitoring System, Tab 9:
2 Why is reliability performance not relevant in this proposal?

3

4

5 A. The justification of this proposal centers on the requirement to address planned
6 obsolescence of the Turbine Supervisory Instrumentation System. Reliability of the
7 specific modules has not been an issue to date.