

1 Q. Re: Replaced Compressed Air Systems, Tab 18:

2 How old is the air compressed system for these breakers?

3

4

5 A. The compressed air systems at both Sunnyside and Stony Brook Terminals Stations
6 are 44 years old.