

- 1 Q. Re: Upgrade Power Transformers – Various Sites, Tab 20:  
2 How often does Hydro use its condition assessment tool to evaluate the oil quality  
3 parameters on its units?  
4  
5
- 6 A. Hydro performs a Dissolved Gas Analysis (DGA) and Oil Quality Analysis on all its  
7 power transformers a minimum of once each year. If a transformer is showing signs  
8 of gassing then the analysis will be done more frequently, depending upon the  
9 gassing level and trend.