

1 Q. With reference to the Project **C-8, Upgrade Governor Controls Units 1 and 2 –**
2 **Holyrood**, could the controller be replaced for one of the Units, without replacing
3 the controller for the other Unit? If the controller for only one of the Units were to
4 be replaced, would parts from the replaced Mark V controller be available as
5 emergency spare parts (in addition to those identified in Table 1, at page 5, Volume
6 I, Tab 3) for the other Mark V controller?

7
8
9 A. The controller for one unit could be replaced and parts which are in good condition
10 on the replaced Mark V controller could be kept as spares for the remaining
11 controller. These parts would increase the number of Mark V spares available but
12 the issue of obsolescence and lack of support would remain.