

1 Q. With reference to the Project **C-12, Complete Condition Assessment Phase 2 (Year**  
2 **2) - Holyrood**, will any component of this Assessment be applicable to Holyrood  
3 once it is fully converted to synchronous condenser mode?  
4

5  
6 A. Yes, all components of this Assessment will be applicable to Holyrood once it is fully  
7 converted to synchronous condenser mode, targeted for completion in 2017. All  
8 components will be applicable up to 2020 as it relates to operating the power  
9 generation systems for exercise purposes and also for emergency generation back-  
10 up as required in the event of power interruption from the new proposed Lower  
11 Churchill project. It is anticipated that after 2020 only those components related to  
12 the electric cable inspection/testing and civil structures will be applicable to  
13 Holyrood as the plant continues to operate with capability of synchronous  
14 condensing only.