

- 1 Q. 2013 Wood Pole Line Management (WPLM), Appendix B. At page B9, Hydro
2 compares its pole replacement rate to the “published data of 0.5 percent to 0.7
3 percent per year for the west coast of North America”.
4
5 (a) Provide a copy of the published data, as published, for the west coast of North
6 America referred to above.
7
8 (b) Over what period has Hydro’s pole replacement rate been 0.33 percent per
9 year?
10
11 (c) What has been Hydro’s pole replacement rate in each year in the period 1993-
12 2011?
13
14
15 A. (a) Please refer to Page 45 of the attachment filed in response to IC-NLH-60 (b).
16
17 (b) Hydro’s pole replacement rate has been 0.33 percent per year since 1999.
18
19 (c) Please see the plot for annual replacement in percentage. As stated in the
20 response to IC-NLH-59, data is available only since 2000.

