

1 Q. C-16, Tab 7: Install Backup System for Raw Water Supply and Clarifier -Holyrood;
2 \$955,600

3 Is a backup system required for synchronous condenser mode of operation and, if
4 so, provide an explanation?

5

6

7 A. Yes, a back-up system is required for a reliable supply of water for fire protection,
8 cooling water, domestic water, and other miscellaneous use both before and after
9 converting to synchronous condensing mode.