

1 Q. (Regulated Activities Evidence page 2.16, lines 4 to 14)
2 Please provide a table showing for each year from 2013 through 2020 the number
3 of hours Holyrood is forecast to be producing energy (exclude voltage support
4 requirements) and the total amount of energy forecast to be produced by
5 Holyrood.

6

7

8 A. Please see the following table which shows, for each year from 2014 through 2020,
9 the number of hours Holyrood is forecast to be producing energy (exclude voltage
10 support requirements) and the total amount of energy forecast to be produced by
11 Holyrood.

12

Table 1

Forecast Holyrood Operating Requirements ⁽¹⁾							
2014 to 2020							
	2014F ⁽²⁾	2015F	2016F	2017F	2018F	2019F	2020F
Holyrood Unit Operating Hours	16,300	14,400	15,500	16,600	10,872	168	168
Holyrood Net Production (GWh)	1,373	1,593	1,651	1,509	821	20	20

Notes: 1. Operating requirements for 2014-2015 are estimated using Hydro's June, 2014 Island Interconnected System Operating Load Forecast (OPLF)
Operating requirements for 2016-2020 are estimated using Hydro's November, 2014 Island Interconnected System Operating Load Forecast (OPLF)

13 It should be noted that during the period of Holyrood standby operation, following
14 the interconnection via the Labrador Island Link (LIL), it is assumed the equivalent
15 of one Holyrood unit will be operated for one week per year - two days at full load
16 and five days at 100 MW.