

1 Q. (Re: Response to IC-NLH-72) The response states "Both requests were denied for
2 reasons unnoted at the time". Has Hydro since found out the reasons why the
3 requests were denied, and if so, what are they?
4
5

6 A. Upon further investigation it has been determined by Hydro that the request on
7 January 25 was not carried out due to the timing of the request and that the
8 arrangements could not be made in time to be in place for the evening peak. The
9 request on January 28 was not carried out following Newfoundland Power's review
10 of its daily load forecast and due to the number of requests to the same curtailable
11 customers that had already taken place.