

1 Q. **IIC Class Demands and Revenues**

2 (Re: Amended GRA) Section 3.2.4, page 17 of Exhibit 9 Lummus Consultants Final
3 Report indicates that Vale monthly power on order will increase to 70.1 MW in
4 2015, 75.3 MW in 2016 and stabilize at 77.6 MW in 2017. Please provide Hydro's
5 latest forecast in this regard.
6
7

8 A. The latest forecast provided to Hydro by Vale was received in February 2015 and
9 indicates Vale power requirements will increase to 44.5 MW in 2015, 61.9 MW in
10 2016 and 75.1 MW in 2017.